

Datum	CSB tot. / BSB5	Verhältnis		Zulauf Rohabwasser Auslastung ARA								Auslastung ARA hydraulisch	
		P tot. / BSB5	NH4-N / BSB5	CSB tot.		BSB5		P tot.		N ges.		Q TW	Q RW
				%	EW	%	EW	%	EW	%	EW	%	%
2012 Anz	128	14	125	131	131	128	128	128	128	0	0	366	366
Minimum	1.35	0.02	0.04	47.0	15980	40.7	13848	39.5	13427			69.2	34.6
Mittelwert	1.94	0.02	0.13	79.2	26923	83.0	28215	71.8	24399			116.5	58.3
Maximum	3.47	0.03	0.25	128.6	43713	116.4	39577	117.6	39981			220.6	110.3
Summe / Total													
2013 Anz	138	84	99	141	141	139	139	148	148	0	0	365	365
Minimum	0.88	0.01	0.08	32.9	11172	39.9	13581	41.8	14214			61.5	30.8
Mittelwert	1.56	0.03	0.14	64.2	21829	83.3	28329	71.1	24175			113.1	56.5
Maximum	2.43	0.04	0.29	108.9	37019	124.2	42219	118.9	40415			229.5	114.7
Summe / Total													
2014 Anz	126	57	121	131	131	127	127	130	130	0	0	365	365
Minimum	0.92	0.01	0.07	36.7	12486	48.7	16547	40.4	13738			60.9	30.5
Mittelwert	1.73	0.03	0.13	72.2	24552	84.8	28320	69.6	23667			109.3	54.6
Maximum	2.32	0.06	0.27	118.7	40371	127.5	43365	163.4	55541			229.7	114.9
Summe / Total													
2015 Anz	87	88	79	108	108	102	102	112	112	0	0	365	365
Minimum	1.11	0.01	0.08	45.4	15443	45.5	15456	44.9	15281			64.9	32.4
Mittelwert	1.84	0.03	0.13	73.9	25116	82.8	28165	67.4	22901			106.6	53.3
Maximum	9.35	0.09	0.22	212.5	72257	148.8	50594	135.6	46110			267.2	133.6
Summe / Total													
2016 Anz	75	73	74	80	80	77	77	78	78	0	0	366	366
Minimum	1.03	0.01	0.05	39.8	13526	27.1	9212	36.1	12266			68.7	34.3
Mittelwert	1.86	0.02	0.12	86.2	29312	94.0	31950	68.7	23375			120.2	60.1
Maximum	2.94	0.04	0.28	143.1	48665	151.5	51508	106.9	36360			236.1	118.1
Summe / Total													
Anzahl	554	316	498	591	591	573	573	596	596	0	0	1827	1827
Minimum	0.88	0.01	0.04	32.9	11172	27.1	9212	36.1	12266			60.9	30.5
Mittelwert	1.77	0.02	0.13	74.0	25175	84.9	28870	69.9	23768			113.1	56.6
Maximum	9.35	0.09	0.29	212.5	72257	151.5	51508	163.4	55541			267.2	133.6
Summe / Total													