

Datum	Absetz- volumen AV ml/l	Trocken- substanz TS g/l	Zulauf TS Online		Zulauf TS Online			Schlamm- vol. index SVI mg/l	Glüh- rückstand GR %	Glüh- verlust GV %	O2-Online			Temperatur Online		
			Kontroll- messung g/l	Ab- weichung %	min. g/l	mit. g/l	max. g/l				min. mg/l	mit. mg/l	max. mg/l	min. °C	mit. °C	max. °C
2012 Anz	248	248	0	0	0	0	0	248	0	0	366	366	366	366	366	366
Minimum	95	0.9						75.0			0.0	1.5	4.0	7.0	7.9	8.9
Mittelwert	277	2.3						117.9			0.1	2.7	7.5	13.7	14.3	14.8
Maximum	460	3.9						189.9			2.2	8.6	12.6	19.8	20.2	32.4
Summe / Total																
2013 Anz	248	248	0	0	0	0	0	248	0	0	365	365	365	365	365	365
Minimum	180	1.8						87.8			0.0	1.1	3.4	6.3	6.9	7.5
Mittelwert	326	2.9						111.5			0.0	2.3	6.2	13.7	14.3	14.8
Maximum	510	3.8						153.1			4.2	7.6	11.9	20.2	20.5	27.2
Summe / Total																
2014 Anz	245	245	0	0	0	0	0	245	0	0	365	365	365	365	365	365
Minimum	200	2.1						85.6			0.0	0.6	3.8	6.8	7.8	9.7
Mittelwert	323	2.9						109.1			0.0	2.1	6.4	14.5	15.1	15.6
Maximum	570	4.4						142.4			0.6	6.5	12.6	19.2	19.7	27.0
Summe / Total																
2015 Anz	251	251	0	0	0	0	0	251	0	0	365	365	365	365	365	365
Minimum	160	1.9						75.3			0.0	1.1	3.2	4.4	7.8	8.2
Mittelwert	269	2.7						97.6			0.1	2.2	4.9	14.5	15.1	15.5
Maximum	400	3.7						133.6			0.7	4.8	12.2	21.3	21.6	29.0
Summe / Total																
2016 Anz	234	234	0	0	0	0	0	234	0	0	366	366	366	366	366	366
Minimum	130	1.4						64.0			0.0	0.7	2.9	0.0	8.0	8.8
Mittelwert	243	2.6						92.5			0.2	1.9	4.7	13.9	14.6	15.1
Maximum	360	3.4						120.8			2.4	3.6	12.6	19.8	20.2	23.8
Summe / Total																
Anzahl	1226	1226	0	0	0	0	0	1226	0	0	1827	1827	1827	1827	1827	1827
Minimum	95	0.9						64.0			0.0	0.6	2.9	0.0	6.9	7.5
Mittelwert	288	2.7						105.8			0.1	2.3	5.9	14.0	14.7	15.2
Maximum	570	4.4						189.9			4.2	8.6	12.6	21.3	21.6	32.4
Summe / Total																