

Datum	Zulauf ARA - Ablauf ARA				
	CSB tot. %	BSB5 %	P tot. %	N ges. %	NH4-N %
<b>1991</b> Anz	46	42	101	0	46
Minimum	69.4	79.5	67.8		0.7
Mittelwert	81.2	89.5	85.9		50.2
Maximum	96.6	96.2	94.3		97.7
<b>Summe / Total</b>					
<b>1992</b> Anz	52	44	102	0	48
Minimum	72.2	75.3	63.1		0.4
Mittelwert	82.0	88.4	88.2		45.1
Maximum	90.0	94.9	95.8		98.9
<b>Summe / Total</b>					
<b>1993</b> Anz	48	47	101	0	42
Minimum	72.8	72.5	78.2		2.6
Mittelwert	85.5	88.3	89.1		44.8
Maximum	93.6	93.6	93.6		98.2
<b>Summe / Total</b>					
<b>1994</b> Anz	50	44	101	0	46
Minimum	75.4	82.6	56.5		6.8
Mittelwert	84.8	89.1	88.8		47.1
Maximum	95.6	94.1	98.8		97.6
<b>Summe / Total</b>					
<b>1995</b> Anz	84	42	129	0	82
Minimum	25.8	76.1	4.7		6.4
Mittelwert	77.2	85.5	80.7		84.2
Maximum	90.6	92.1	97.6		99.9
<b>Summe / Total</b>					
<b>1996</b> Anz	45	43	123	0	45
Minimum	64.7	81.4	63.9		8.2
Mittelwert	82.7	89.8	85.2		41.6
Maximum	91.6	95.4	97.1		98.2
<b>Summe / Total</b>					
Anzahl	325	262	657	0	309
Minimum	25.8	72.5	4.7		0.4
Mittelwert	81.7	88.4	86.0		56.0
Maximum	96.6	96.2	98.8		99.9
<b>Summe / Total</b>					