

Datum	Faulraum								Faulraum Auslauf				Trüb- wasser Menge m³
	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	Abbau- leistung %	Temp. vor WT °C	pH-Wert pH	Organ. Säure mg/l	Faulzeit d	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	pH-Wert %	
2002 Anz	51	51	51	51	365	51	0	365	51	51	51	51	0
Minimum	2.5	43.8	46.5	51.3	32.0	6.2		20.0	3.0	48.1	44.5	6.8	
Mittelwert	4.5	50.3	49.7	62.8	33.1	6.5		24.7	5.5	51.6	48.4	7.3	
Maximum	5.6	53.5	56.2	76.2	35.1	7.2		25.0	7.2	55.5	51.9	7.6	
Summe / Total													
2003 Anz	49	49	49	49	365	49	0	365	50	49	49	49	0
Minimum	2.2	45.2	46.8	46.3	31.0	6.4		15.4	2.5	46.2	46.8	7.1	
Mittelwert	3.5	48.9	51.1	61.4	34.6	7.0		22.8	4.3	49.9	50.1	7.4	
Maximum	5.7	53.3	54.8	75.2	38.8	7.4		35.7	6.6	53.2	53.8	7.6	
Summe / Total													
2004 Anz	52	52	52	52	366	52	0	366	52	52	52	52	0
Minimum	2.0	44.6	47.5	48.8	36.5	7.1		15.6	2.2	47.1	45.1	7.2	
Mittelwert	2.6	48.5	51.5	64.8	37.5	7.3		22.5	3.3	50.4	49.6	7.5	
Maximum	3.7	52.5	55.4	78.8	38.7	7.5		33.3	5.1	54.9	52.9	7.7	
Summe / Total													
2005 Anz	51	51	51	51	365	51	0	365	51	51	51	51	0
Minimum	2.1	46.9	44.7	41.4	30.7	7.2		13.0	2.3	48.2	42.8	7.2	
Mittelwert	2.8	49.5	50.5	67.8	37.0	7.3		20.6	3.9	51.4	48.6	7.4	
Maximum	4.2	55.3	53.1	80.2	38.3	7.5		35.7	6.6	57.3	51.8	7.7	
Summe / Total													
2006 Anz	49	49	49	49	365	49	0	365	48	48	48	49	29
Minimum	2.0	41.5	47.9	38.4	33.1	7.1		11.2	2.5	44.2	41.5	7.2	7.0
Mittelwert	2.5	47.0	53.0	58.8	37.2	7.3		21.2	3.7	50.0	50.0	7.4	38.4
Maximum	3.0	52.1	58.5	70.8	39.2	7.5		33.3	5.2	58.5	55.8	7.7	140.0
Summe / Total													1114.0
Anzahl	252	252	252	252	1826	252	0	1826	252	251	251	252	29
Minimum	2.0	41.5	44.7	38.4	30.7	6.2		11.2	2.2	44.2	41.5	6.8	7.0
Mittelwert	3.2	48.9	51.1	63.2	35.9	7.1		22.4	4.1	50.7	49.3	7.4	38.4
Maximum	5.7	55.3	58.5	80.2	39.2	7.5		35.7	7.2	58.5	55.8	7.7	140.0
Summe / Total													1114.0