

Datum	Faulraum								Faulraum Auslauf				Trüb- wasser Menge m³
	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	Abbau- leistung %	Temp. vor WT °C	pH-Wert pH	Organ. Säure mg/l	Faulzeit d	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	pH-Wert %	
2007 Anz	49	48	48	48	365	47	0	365	48	48	48	47	111
Minimum	2.3	40.9	46.5	22.5	35.0	7.1		16.4	2.3	42.1	44.0	7.2	2.0
Mittelwert	2.8	45.4	54.6	57.2	37.2	7.2		22.6	3.1	48.9	51.1	7.4	28.6
Maximum	3.4	53.5	59.1	70.7	38.7	7.5		45.7	4.3	56.0	57.9	7.7	122.0
Summe / Total													3175.0
2008 Anz	50	50	50	50	366	50	0	366	49	49	49	49	94
Minimum	2.6	39.8	50.1	29.4	34.9	7.1		18.0	2.1	40.4	49.7	7.1	0.0
Mittelwert	2.9	44.7	55.3	56.9	37.1	7.3		22.6	3.0	47.5	52.5	7.5	15.5
Maximum	3.3	49.9	60.2	67.9	37.6	7.4		38.8	6.2	50.3	59.6	7.6	45.0
Summe / Total													1455.0
2009 Anz	51	51	51	51	365	51	0	365	51	51	51	51	120
Minimum	2.2	39.7	49.3	35.1	35.8	6.8		15.6	2.2	40.5	47.4	6.8	0.0
Mittelwert	2.9	44.3	55.7	53.9	36.9	7.2		20.8	3.0	46.7	53.3	7.4	13.2
Maximum	3.5	50.7	60.3	66.6	38.1	7.4		24.6	3.8	52.6	59.5	7.7	104.0
Summe / Total													1586.1
2010 Anz	52	52	52	52	365	52	18	365	51	51	51	51	39
Minimum	2.7	40.3	47.8	37.0	36.5	7.0	90.0	16.3	2.5	43.7	45.6	7.1	0.0
Mittelwert	3.1	45.3	54.7	56.1	38.4	7.2	139.2	21.1	3.1	47.7	52.3	7.4	10.4
Maximum	3.6	52.2	59.7	67.5	39.1	7.4	218.0	26.7	4.0	54.4	56.3	7.6	23.0
Summe / Total													405.0
2011 Anz	53	53	53	53	365	53	49	365	53	53	53	53	0
Minimum	2.7	40.3	46.6	44.0	37.7	7.0	90.2	17.8	2.5	42.0	44.8	7.2	
Mittelwert	3.0	44.5	55.5	58.3	38.6	7.2	122.1	22.5	3.0	46.7	53.3	7.3	
Maximum	3.6	53.4	59.7	69.5	39.1	7.4	178.0	30.2	4.3	55.2	58.0	7.4	
Summe / Total													
Anzahl	255	254	254	254	1826	253	67	1826	252	252	252	251	364
Minimum	2.2	39.7	46.5	22.5	34.9	6.8	90.0	15.6	2.1	40.4	44.0	6.8	0.0
Mittelwert	3.0	44.8	55.2	56.5	37.6	7.2	126.7	21.9	3.0	47.5	52.5	7.4	18.2
Maximum	3.6	53.5	60.3	70.7	39.1	7.5	218.0	45.7	6.2	56.0	59.6	7.7	122.0
Summe / Total													6621.1