

Datum	Faulraum								Faulraum Auslauf				Trüb- wasser Menge m³
	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	Abbau- leistung %	Temp. vor WT °C	pH-Wert pH	Organ. Säure mg/l	Faulzeit d	Trocken- rückstand %	Glüh- rückstand %	Glüh- verlust %	pH-Wert %	
Jan 2017 Anz	5	5	5	5	31	5	1	31	5	5	5	5	0
Mittelwert	2.6	40.0	60.0	63.1	38.7	7.2	269.0	20.0	2.5	43.8	56.2	7.5	
Feb 2017 Anz	4	4	4	4	28	4	1	28	4	4	4	4	0
Mittelwert	2.8	42.4	57.6	55.9	38.6	7.3	284.0	20.3	2.5	43.7	56.3	7.5	
Mrz 2017 Anz	3	3	3	3	31	3	1	31	3	3	3	3	0
Mittelwert	2.8	43.0	57.0	59.6	38.7	7.4	299.0	20.1	2.8	46.0	54.0	7.6	
Apr 2017 Anz	4	4	4	4	30	4	1	30	4	4	4	4	0
Mittelwert	2.8	41.5	58.5	52.2	38.7	7.4	372.0	20.7	2.6	43.2	56.8	7.6	
Mai 2017 Anz	5	5	5	5	31	6	1	31	5	5	5	5	0
Mittelwert	2.7	41.7	58.3	52.2	38.8	7.3	296.0	21.7	2.5	43.5	56.5	7.6	
Jun 2017 Anz	4	4	4	4	30	4	2	30	4	4	4	4	0
Mittelwert	2.8	41.5	58.5	48.9	38.8	7.3	285.0	21.0	2.6	43.9	56.1	7.6	
Jul 2017 Anz	4	4	4	4	31	4	1	31	4	4	4	4	0
Mittelwert	3.0	42.1	57.9	49.1	38.8	7.3	217.0	20.4	2.8	44.0	56.0	7.5	
Aug 2017 Anz	5	5	5	5	31	5	0	31	5	5	5	5	0
Mittelwert	2.6	42.2	57.9	56.2	38.8	7.3		21.2	2.5	44.6	55.4	7.6	
Sep 2017 Anz	4	4	4	4	30	4	2	30	4	4	4	4	0
Mittelwert	2.7	45.6	54.4	53.4	38.7	7.3	216.0	20.0	2.6	46.3	53.7	7.5	
Okt 2017 Anz	5	5	5	5	31	5	0	31	5	5	5	5	0
Mittelwert	2.9	44.5	55.6	54.2	38.8	7.3		20.9	2.7	45.8	54.2	7.6	
Nov 2017 Anz	4	4	4	4	30	4	0	30	4	4	4	4	0
Mittelwert	2.8	43.5	56.5	58.9	38.6	7.3		20.9	2.6	45.6	54.4	7.6	
Dez 2017 Anz	3	3	3	3	31	3	0	31	3	3	3	3	0
Mittelwert	2.7	41.3	58.7	60.2	38.7	7.4		20.5	2.5	42.7	57.3	7.6	
Anzahl	50	50	50	50	365	51	10	365	50	50	50	50	0
Minimum	2.5	38.7	53.6	25.1	36.8	7.2	214.0	12.4	2.2	39.8	52.2	7.5	
Mittelwert	2.8	42.4	57.6	55.2	38.7	7.3	273.9	20.6	2.6	44.4	55.6	7.6	
Maximum	3.3	46.4	61.3	64.2	38.9	7.4	372.0	23.9	3.0	47.8	60.2	7.7	
Summe / Total													